

VERIFICHE SETTI PIANO SECONDO

lunghezza infissione solaio = 25 cm (Si ipotizza il cordolo di testa in c.a. di spessore circa 25cm)												
	spess (t) (cm)	e acc (cm)	d s (cm)	ecc s (cm)	e tot = (cm)	m =	lamda =	φ =	N max (Kg)	Area (cmq)	sig max= (Kg/cmq)	
1	57	1.5			1.5	0.16	5.3	0.88	4224	5700	0.84	
2	52	1.5	13.5	2.0	3.5	0.41	5.8	0.71	5620	7020	1.13	
3	48	1.5			1.5	0.19	6.3	0.84	10845	13536	0.95	
4	50	1.5			1.5	0.18	6.0	0.86	3088	3750	0.96	
5	50	1.5			1.5	0.18	6.0	0.86	13785	17350	0.92	
6	54	1.5			1.5	0.17	5.6	0.87	2510	2916	0.99	
7	54	1.5	14.5	3.2	4.7	0.53	5.6	0.66	4919	5508	1.35	
8	54	1.5	14.5	8.0	9.5	1.06	5.6	0.48	7568	6318	2.50	
9	58	1.5	16.5	4.9	6.4	0.66	5.2	0.62	8427	9048	1.50	
10	54	1.5	14.5	6.5	8.0	0.88	5.6	0.53	8757	7452	2.22	
11	58	1.5	16.5	8.8	10.3	1.07	5.2	0.48	7201	5858	2.56	
12	58	1.5	16.5	4.7	6.2	0.64	5.2	0.63	6954	7714	1.43	
13	45	1.5			1.5	0.20	6.7	0.83	2249	2565	1.06	
14	57	1.5			1.5	0.16	5.3	0.88	14542	18354	0.90	
15	57	1.5			1.5	0.16	5.3	0.88	4296	3933	1.24	
16	48	1.5			1.5	0.19	6.3	0.84	11301	14016	0.96	
17	53	1.5	14.0	4.0	5.5	0.62	5.7	0.63	4480	4293	1.66	
18	56	1.5	15.5	8.4	9.9	1.06	5.4	0.48	19490	16800	2.42	
19	56	1.5	15.5	7.0	8.5	0.91	5.4	0.53	6806	4760	2.70	
20	35	1.5	5.0	2.5	4.0	0.69	8.6	0.56	9824	6580	2.67	
21	35	1.5	5.0	3.3	4.8	0.82	8.6	0.52	5692	3745	2.92	
22	57	1.5			1.5	0.16	5.3	0.88	50205	25137	2.27	
23	54	1.5			1.5	0.17	5.6	0.87	40708	29052	1.61	
24	57	1.5			1.5	0.16	5.3	0.88	12135	13281	1.04	
25	55	1.5			1.5	0.16	5.5	0.88	2803	3135	1.02	
26												
27												
28												
29												
30												
31												
32												
33												

P.1
P.2
P.3
P.4