

**VERIFICHE SETTI PIANO TERRA**

<b>lunghezza infissione solaio = 25 cm (infissione travi nella muratura di circa 25cm)</b>											
	spess (t) (cm)	e acc (cm)	d s (cm)	ecc s (cm)	e tot = (cm)	m =	lamda =	φ =	N max (Kg)	Area (cmq)	sig max= (Kg/cmq)
1	57	1.5			1.5	0.16	5.3	0.88	12671	5700	<b>2.53</b>
2	52	1.5	17.7	6.7	8.2	0.95	5.8	0.46	71042	31928	<b>4.84</b>
3											
4	42	1.5			1.5	0.21	7.1	0.82	6976	2646	<b>3.21</b>
5	63	1.5			1.5	0.14	4.8	0.9	63416	31059	<b>2.27</b>
6											
7	60	1.5	21.7	1.2	2.7	0.27	5.0	0.7	16283	6120	<b>3.80</b>
8	60	1.5	21.7	2.6	4.1	0.41	5.0	0.72	25079	6480	<b>5.38</b>
9	60	1.5	21.7	3.0	4.5	0.45	5.0	0.69	25998	6840	<b>5.51</b>
10	60	1.5	10.0	3.3	4.8	0.48	5.0	0.69	42500	14760	<b>4.17</b>
11	60	1.5	10.0	2.5	4.0	0.40	5.0	0.74	27446	6840	<b>5.42</b>
12	60	1.5			1.5	0.15	5.0	0.89	22486	7980	<b>3.17</b>
13	49	1.5			1.5	0.18	6.1	0.85	7765	2793	<b>3.27</b>
14	57	1.5			1.5	0.16	5.3	0.88	44727	17727	<b>2.87</b>
15	65	1.5			1.5	0.14	4.6	0.9	162455	47060	<b>3.84</b>
16											
17	53	1.5	18.2	7.1	8.6	0.97	5.7	0.52	58949	20511	<b>5.53</b>
18											
19											
20											
21											
22											
23											
24	60	1.5			1.5	0.15	5.0	0.89	47571	16800	<b>3.18</b>
25											
26	52	1.5			1.5	0.17	5.8	0.86	3743	3900	<b>1.12</b>
27	52	1.5			1.5	0.17	5.8	0.86	7353	6188	<b>1.38</b>
28	65	1.5			1.5	0.14	4.6	0.88	48060	12025	<b>4.54</b>
29	65	1.5			1.5	0.14	4.6	0.88	46694	12545	<b>4.23</b>
30	51	1.5			1.5	0.18	5.9	0.86	12024	3162	<b>4.42</b>
31	62	1.5			1.5	0.15	4.8	0.89	20222	6696	<b>3.39</b>
32	52	1.5			1.5	0.17	5.8	0.86	10797	3276	<b>3.83</b>
33	63	1.5			1.5	0.14	4.8	0.9	17269	6363	<b>3.02</b>
P.1									18680		
P.2									21234		
P.3											
P.4											

**N.B: PER SETTI 9, 10 E 15 Scarico volta a 10cm dal baricentro**